



Issuance Date: August 11, 2009
Effective Date: September 1, 2009
Expiration Date: August 31, 2014

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
WASTE DISCHARGE PERMIT NO. WA0037079

State of Washington
DEPARTMENT OF ECOLOGY
Olympia, Washington 98504-7775

In compliance with the provisions of
The State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington
and
The Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1251 et seq.

Cherrywood Mobile Home Manor
Dr. Barry Kaimakis and Mr. Bill Kaimakis
One Union Square
600 University Street, Suite 804
Seattle, Washington 98101

Plant Location: 8412 38th Street East
Puyallup, WA 98371

Receiving Water: Wapato Creek

Water Body I.D. No.: WA-10-1015

Discharge Location:

Latitude: 47° 13' 29" N

Longitude: 122 ° 19' 03" W

Plant Type: Activated Sludge

is authorized to discharge in accordance with the special and general conditions that follow.

Garin Schrieve, P.E.
Southwest Region Manager
Water Quality Program
Washington State Department of Ecology

TABLE OF CONTENTS

	<u>Page</u>
SUMMARY OF PERMIT REPORT SUBMITTALS	4
SPECIAL CONDITIONS	
S1. DISCHARGE LIMITATIONS	5
A. Effluent Limitations	
S2. MONITORING REQUIREMENTS	6
A. Monitoring Schedule	
B. Sampling and Analytical Procedures	
C. Flow Measurement	
D. Laboratory Accreditation	
S3. REPORTING AND RECORDKEEPING REQUIREMENTS	8
A. Reporting	
B. Records Retention	
C. Recording of Results	
D. Additional Monitoring by the Permittee	
E. Reporting Permit Violations	
F. Other Reporting	
G. Maintaining a Copy of this Permit	
S4. FACILITY LOADING	11
A. Design Criteria	
B. Prohibition of New or Altered Sources	
C. Infiltration and Inflow Reduction	
D. Wasteload Assessment	
E. Connection to Public Sewers	
S5. OPERATION AND MAINTENANCE	13
A. Certified Operator	
B. O & M Program	
C. Short-term Reduction	
D. Electrical Power Failure	
E. Prevent Connection of Inflow	
F. Bypass Procedures	
G. Operations and Maintenance Manual	
S6. RESIDUAL SOLIDS	15
S7. RECEIVING WATER STUDY OF TEMPERATURE	
GENERAL CONDITIONS	
G1. SIGNATORY REQUIREMENTS	17
G2. RIGHT OF ENTRY	17
G3. PERMIT ACTIONS	18
G4. REPORTING A CAUSE FOR MODIFICATION	18

G5. PLAN REVIEW REQUIRED 18

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES 18

G7. DUTY TO REAPPLY 19

G8. REMOVED SUBSTANCES 19

G9. TOXIC POLLUTANTS..... 19

G10. OTHER REQUIREMENTS OF 40 CFR..... 19

G11. ADDITIONAL MONITORING 19

G12. PAYMENT OF FEES..... 19

G13. PENALTIES FOR VIOLATING PERMIT CONDITIONS..... 19

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.	Discharge Monitoring Report	Monthly	October 15, 2009
S3.E	Reporting Permit Violations	As necessary	
S4.C.	Infiltration and Inflow Evaluation	Annual	January 15, 2010
S4.D.	Wasteload Assessment	Annual	January 15, 2010
S4.E.	Plan to Connect to Public Sewers	Annual	April 15, 2010
S5.G.	O&M Manual Update/Review Letter	Annual	January 15, 2010
S7.A.	Quality Assurance Project Plan for Effluent and Receiving Water Temperature Study	1/permit cycle	December 31, 2009
S7.H.	Temperature Study Data Report	Annually	December 31, 2010
G1.	Notice of Change in Authorization	as necessary	
G4.	Permit Application for Substantive Changes to the Discharge	As necessary	
G5.	Engineering Report for Construction or Modification Activities	As necessary	
G7.	Application for permit renewal	1/permit cycle	March 1, 2014

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS

A. Effluent Limitations:

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on the effective date of this permit and lasting through the expiration date the Permittee is authorized to discharge municipal wastewater at the permitted location subject to the following limitations:

EFFLUENT LIMITATIONS ^a : OUTFALL # 001		
Parameter	Average Monthly	Average Weekly
Biochemical Oxygen Demand ^b (5 day)	15 mg/L, 2 lbs/day 85% removal of influent concentration	23 mg/L, 3 lbs/day
Total Suspended Solids ^b	15 mg/L, 2 lbs/day 85% removal of influent concentration	23 mg/L, 3 lbs/day
Fecal Coliform Bacteria	100 cfu/100 mL	200 cfu/100 mL
pH	Daily minimum is equal to or greater than 6.5 and the daily maximum is less than or equal to 8.5 standard units.	
Parameter	Average Monthly	Maximum Daily ^c
Total Residual Chlorine	0.007 mg/L	0.018 mg/L
Total Ammonia (as NH ₃ -N) June 1 through October 31	0.8 mg/L	1.8 mg/L
^a The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform, which is based on the geometric mean.		
^b The average monthly effluent concentration for BOD ₅ and Total Suspended Solids shall not exceed 15 mg/L or 15 percent of the respective monthly average influent concentrations, whichever is more stringent.		
^c The maximum daily effluent limitation is defined as the highest allowable daily discharge. The daily discharge means the average measurement of the pollutant over a calendar day		

S2. MONITORING REQUIREMENTS

A. Monitoring Schedule:

Category	Parameter	Units	Sample Point	Minimum Sampling Frequency	Sample Type
Wastewater Influent	Flow	MGD	Pump Hours	Continuous ^a	Calculate
Wastewater Influent	BOD ₅	mg/L lbs/day	Influent Sampler	1/week	24-Hour Composite
Wastewater Influent	TSS	mg/L lbs/day	Influent Sampler	1/week	24-Hour Composite
Wastewater Effluent	BOD ₅	mg/L lbs/day % Removal	Final Effluent	1/week	24-Hour Composite
Wastewater Effluent	TSS	mg/L lbs/day % Removal	Final Effluent	1/week	24-Hour Composite
Wastewater Effluent	Total Residual Chlorine	mg/L	Before Dechlorination	5/week	Grab
Wastewater Effluent	Total Residual Chlorine	mg/L	After Dechlorination	5/week	Grab
Wastewater Effluent	Total Ammonia as NH ₃ -N	mg/L	Final Effluent	1/week	Grab
Wastewater Effluent	Fecal Coliform	Cfu/100mL	Final Effluent	1/week	Grab
Wastewater Effluent	pH	Standard Units	Final Effluent	5/week	Grab
Wastewater Effluent	Temperature	Deg C	Final Effluent	5/week	Grab
Wastewater Effluent	Ammonia as N	mg/L	Final Effluent	Quarterly ^b	Grab
Wastewater Effluent	Nitrite as N	mg/L	Final Effluent	Quarterly ^b	Grab
Wastewater Effluent	Nitrate as N	mg/L	Final Effluent	Quarterly ^b	Grab
Wastewater Effluent	TKN	mg/L	Final Effluent	Quarterly ^b	Grab

Category	Parameter	Units	Sample Point	Minimum Sampling Frequency	Sample Type
Wastewater Effluent	Ortho-phosphate (PO ₄)	mg/L	Final Effluent	Quarterly ^b	Grab
Wastewater Effluent	Total Phosphorus	mg/L	Final Effluent	Quarterly ^b	Grab
^a Continuous means uninterrupted except for brief lengths of time for calibration, for power failure, or for unanticipated equipment repair or maintenance. Sampling shall be taken once per day when continuous monitoring is not possible.					
^b Quarterly is defined as: January through March (report with March DMR) April through June (report with June DMR) July through September (report with September DMR) October through December (report with December DMR)					
The Permittee shall inspect monthly the condition of the outfall line and document its integrity and continued function on the Discharge Monitoring Report submitted to the Department of Ecology.					

B. Sampling and Analytical Procedures:

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 Code of Federal Regulations (CFR) Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Ecology).

C. Flow Measurement:

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. Within 90 days after permit issuance, the devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.

D. Laboratory Accreditation:

All monitoring data required by Ecology shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 Washington Administrative Code (WAC). Flow, temperature, settleable solids,

conductivity, pH, and internal process control parameters are exempt from this requirement. Conductivity and pH shall be accredited if the laboratory must otherwise be registered or accredited. Crops, soils and hazardous waste data are exempted from this requirement pending accreditation of laboratories for analysis of these media by Ecology.

S3. REPORTING AND RECORDKEEPING REQUIREMENTS

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on the effective date of the permit. The Permittee must:

1. Submit monitoring results each month.
2. Summarize, report, and submit monitoring data obtained during each monitoring period on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, by Ecology.
3. Submit DMR forms monthly whether or not the facility was discharging. If the facility did not discharge during a given monitoring period, submit the form as required with the words "NO DISCHARGE" entered in place of the monitoring results.
4. Ensure that DMR forms are postmarked or received by Ecology no later than the 15th day of the month following the completed monitoring period, unless otherwise specified in this permit.
5. Send report(s) to Ecology at:

Water Quality Permit Coordinator
Department of Ecology
Southwest Regional Office
P.O. Box 47775
Olympia, WA 98504-7775

All laboratory reports providing data for organic and metal parameters must include the following information: sampling date, sample location, date of analysis, parameter name, CAS number, analytical method/number, method detection limit (MDL), laboratory practical quantitation limit (PQL), reporting units, and concentration detected. Analytical results from samples sent to a contract laboratory must include information on the chain of custody, the analytical method, QA/QC results, and documentation of accreditation for the parameter.

B. Records Retention

The Permittee must retain records of all monitoring information for a minimum of three years. Such information must include all calibration and maintenance records and all

original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

C. Recording of Results

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.
2. The individual who performed the sampling or measurement.
3. The dates the analyses were performed.
4. The individual who performed the analyses.
5. The analytical techniques or methods used.
6. The results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR.

E. Reporting Permit Violations

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

- Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
- If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology within 30 days of sampling.

1. Immediate Reporting

The Permittee must report any failure of the disinfection system immediately to the Department of Ecology's Regional Office 24-hour number listed below:

Southwest Regional Office 360-407-6300

2. Twenty-Four (24)-Hour Reporting

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at 360-407-6300, within 24 hours from the time the Permittee becomes aware of any of the following circumstances:

- a. Any noncompliance that may endanger health or the environment, unless previously reported under subpart 1, above.
- b. Any unanticipated **bypass** that exceeds any effluent limitation in the permit (See Part S4.B., "Bypass Procedures").
- c. Any **upset** that exceeds any effluent limitation in the permit (See G.15, "Upset").
- d. Any violation of a maximum daily or instantaneous maximum discharge limitation for any of the pollutants in Section S1.A of this permit.
- e. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limitation in the permit.

3. Report Within Five Days

The Permittee must also provide a written submission within five days of the time that the Permittee becomes aware of any event required to be reported under subparts 1 or 2, above. The written submission must contain:

- a. A description of the noncompliance and its cause.
- b. The period of noncompliance, including exact dates and times.
- c. The estimated time noncompliance is expected to continue if it has not been corrected.
- d. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- e. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

4. Waiver of Written Reports

Ecology may waive the written report required in subpart 3, above, on a case-by-case basis upon request if a timely oral report has been received.

5. All Other Permit Violation Reporting

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A

("Reporting"). The reports must contain the information listed in paragraph E.3, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

6. Report Submittal

The Permittee must submit reports to the address listed in S3.

F. Other Reporting

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of RCW 90.56.280 and chapter 173-303-145. You can obtain further instructions at the following website:

<http://www.ecy.wa.gov/programs/spills/other/reportaspill.htm>.

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

The Permittee must submit a new application or supplement at least 180 days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include: any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

G. Maintaining a Copy of this Permit

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

S4. FACILITY LOADING

A. Design Criteria:

Flows or waste loadings of the following design criteria for the permitted treatment facility shall not be exceeded:

Average flow for the maximum month:	16,000 gpd
BOD ₅ loading for maximum month:	40 lbs/day
TSS loading for maximum month:	40 lbs/day
Design population equivalent	200 residents/80 mobile

B. Prohibition of New or Altered Sources:

Any new discharge or increase in volume or change in character of an existing discharge into the sewer which: (1) would interfere with the operation of, or exceed the design capacity of any portion of the collection or treatment system; (2) is not part of approved

engineering plans and specifications; or (3) would be subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act is prohibited.

C. Infiltration and Inflow Reduction:

1. The Permittee shall conduct an infiltration and inflow (I/I) evaluation. Refer to the U.S.EPA publication, *I/I Analysis and Project Certification*, available as Publication No. 97-03 at: Publications Office, Department of Ecology, P.O. Box 47600, Olympia, WA, 98504-7600. Plant monitoring records may be used to assess measurable infiltration and inflow (I/I).
2. A report shall be prepared which summarizes any measurable infiltration I/I. If I/I have increased by more than 15 percent from that found in the first report based on equivalent rainfall, the report shall contain a plan and a schedule for: (1) locating the sources of I/I; and (2) correcting the problem.
3. The report covering the previous year from November 1st through October 31st shall be submitted by **January 15, 2010**, and **annually** thereafter.

D. Wasteload Assessment

1. The Permittee must conduct an annual assessment of their influent flow and wasteload and submit a report to Ecology by **January 15, 2010**, and **annually** thereafter.
2. The report must contain the following: an indication of compliance or noncompliance with the permit effluent limits; a comparison between the existing and design monthly average dry weather and wet weather flows, peak flows, BOD, and total suspended solids loadings; and the percentage change in these parameters since the previous report.
3. The report must also state the present and design population or population equivalent, projected population growth rate, and the estimated date upon which the design capacity is projected to be reached, according to the most restrictive of the parameters above.
4. Ecology may modify the interval for review and reporting if it determines that a different frequency is sufficient.

E. Connection to Public Sewers:

The Permittee shall remove this discharge from Wapato Creek and connect to public sewers as soon as service is available to the area.

By **April 15, 2010**, and **annually** thereafter, the Permittee shall submit a report to Ecology summarizing the feasibility of connection to public sewers. The report shall contain a plan and schedule to connect to public sewers at the earliest opportunity. The plan shall also include necessary upgrades to pump stations and collection system needed to meet requirements to connect to public sewers.

S5. OPERATION AND MAINTENANCE

The Permittee shall at all times be responsible for the proper operation and maintenance of any facilities or systems of control installed to achieve compliance with the terms and conditions of the permit.

A. Certified Operator:

The Permittee shall provide an adequate operating staff which is qualified to carry out the operation, maintenance and testing activities required to insure compliance with the conditions of this permit. An operator certified for at least a Class II plant by the state of Washington shall be in responsible charge of the day-to-day operation of the wastewater treatment plant.

B. O & M Program:

The Permittee shall institute an adequate operation and maintenance program for their entire sewage system. Maintenance records shall be maintained on all major electrical and mechanical components of the treatment plant. Maintenance records shall also be maintained for the collection system and pumping stations including sewer cleaning, repairs and pump station maintenance. All records shall clearly specify the frequency and type of maintenance recommended by the manufacturer and shall show the frequency and type of maintenance performed.

These maintenance records shall be available for inspection at all times.

C. Short-term Reduction:

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limitations on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee shall give written notification to Ecology, if possible, 30 days prior to such activities, detailing the reasons for, length of time of, and the potential effects of the reduced level of treatment. This notification does not relieve the Permittee of their obligations under this permit.

D. Electrical Power Failure:

The Permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations either by means of alternate power sources, standby generator, or retention of inadequately treated wastes. The Permittee shall maintain Reliability Class II (EPA 430-99-74-001) at the wastewater treatment plant, which requires primary sedimentation and disinfection.

E. Prevent Connection of Inflow:

The Permittee shall strictly enforce their sewer use regulations and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

F. Bypass Procedures:

The Permittee shall immediately notify Ecology of any spill, overflow, or bypass from any portion of the collection or treatment system.

The bypass of wastes from any portion of the treatment system is prohibited unless one of the following conditions (1, 2, or 3) applies:

1. Unavoidable Bypass -- Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.

If the resulting bypass from any portion of the treatment system results in noncompliance with this permit the Permittee shall notify Ecology in accordance with condition S3.E "Noncompliance Notification."

2. Anticipated Bypass That Has The Potential to Violate Permit Limits or Conditions -- Bypass is authorized by an administrative order issued by Ecology. The Permittee shall notify Ecology at least 30 days before the planned date of bypass. The notice shall contain (1) a description of the bypass and its cause; (2) an analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing; (3) a cost-effectiveness analysis of alternatives including comparative resource damage assessment; (4) the minimum and maximum duration of bypass under each alternative; (5) a recommendation as to the preferred alternative for conducting the bypass; (6) the projected date of bypass initiation; (7) a statement of compliance with SEPA; (8) if a water quality criteria exceedance is unavoidable, a request for modification of water quality standards as provided for in WAC 173-201A-110, and (9) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

For probable construction bypasses, the need to bypass is to be identified as early in the planning process as possible. The analysis required above shall be considered during preparation of the engineering report or facilities plan and plans and specifications and shall be included to the extent practical. In cases where the probable need to bypass is determined early, continued analysis is necessary up to and including the construction period in an effort to minimize or eliminate the bypass.

Ecology will consider the following prior to issuing an administrative order:

- a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of the permit.
- b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.

- c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, Ecology will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by Ecology under Revised Code of Washington (RCW) 90.48.120.

3. Bypass For Essential Maintenance Without the Potential to Cause Violation of Permit Limits or Conditions -- Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of the permit, or adversely impact public health as determined by Ecology prior to the bypass.

G. Operations and Maintenance Manual:

The approved Operations and Maintenance (O&M) Manual shall be kept available at the treatment plant and all operators shall follow the instructions and procedures of this Manual.

The O&M Manual shall be reviewed by the Permittee at least annually and the Permittee shall confirm this review by letter and/or a manual update to Ecology by **January 15, 2010**, and **annually** thereafter. Substantial changes or updates to the O&M Manual shall be submitted to Ecology whenever they are incorporated into the Manual.

The O&M Manual shall include:

1. Emergency procedures for plant shutdown and cleanup in event of wastewater system upset or failure;
2. Plant maintenance procedures;
3. The treatment plant process control monitoring schedule;

S6. RESIDUAL SOLIDS

Residual solids include screenings, grit, scum, primary sludge, waste activated sludge and other solid waste. The Permittee shall store and handle all residual solids in such a manner so as to prevent their entry into state ground or surface waters. The Permittee shall not discharge leachate from residual solids to state surface or ground waters.

S7. RECEIVING WATER STUDY OF TEMPERATURE

The Permittee must collect information on the effluent and receiving water to determine if the effluent has a reasonable potential to cause a violation of the water quality standards. If reasonable potential exists, Ecology will use this information to calculate effluent limits.

The Permittee must:

- A. Submit a Sampling Quality Assurance Project Plan for Ecology review and approval by **December 31, 2009**.
- B. Conduct all sampling and analysis in accordance with the guidelines given in *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies*, Ecology Publication 04-03-030 (<http://www.ecy.wa.gov/pubs/0403030.pdf>).

A model Quality Assurance Plan specific for temperature is available at <http://www.ecy.wa.gov/programs/wq/permits/guidance.html>.
- C. Measure temperature in the final effluent and the ambient water upstream of the outfall during the months of June through October of each year, beginning **June 1, 2010**.
- D. Use micro-recording temperature devices known as thermistors to measure temperature. Ecology's Quality Assurance Project Plan Development Tool (*Continuous Temperature Sampling Protocols for the Environmental Monitoring and Trends*) contains protocols for continuous temperature sampling. This document is available online at <http://www.ecy.wa.gov/programs/eap/qa/docs/QAPPtool/Mod6%20Ecology%20SOPs/Protocols/ContinuousTemperatureSampling.pdf>.
- E. Calibrate the devices as specified in this document unless using recording devices which are certified by the manufacturer. Ecology does not require manufacture-specific equipment as given in this document however; if the Permittee wishes to use measuring devices from another company, it must demonstrate the accuracy is equivalent.
- F. Set the recording devices to record at one-half-hour intervals.
- G. Report temperature monitoring data as: daily maximum, seven-day running average of the daily maximums, and the monthly maximum of the seven-day running average. The model Quality Assurance Plan shows an example of these calculations.
- H. Submit the temperature data for each June through October period by December 31st of the monitoring year. The First report is due **December 31, 2010**, and **annually** thereafter.

GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to Ecology shall be signed and certified.

- A. All permit applications shall be signed by either a principal executive officer or a ranking elected official.
- B. All reports required by this permit and other information requested by Ecology shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by a person described above and submitted to Ecology, and
 - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- C. Changes to authorization. If an authorization under paragraph B.2. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of B.2. must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

G2. RIGHT OF ENTRY

The Permittee shall allow an authorized representative of Ecology, upon the presentation of credentials and such other documents as may be required by law:

- A. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit;

- B. To have access to and copy at reasonable times any records that must be kept under the terms of the permit;
- C. To inspect at reasonable times any monitoring equipment or method of monitoring required in the permit;
- D. To inspect at reasonable times any collection, treatment, pollution management, or discharge facilities; and
- E. To sample at reasonable times any discharge of pollutants.

G3. PERMIT ACTIONS

This permit shall be subject to modification, suspension, or termination, in whole or in part by Ecology for any of the following causes:

- A. Violation of any permit term or condition;
- B. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
- C. A material change in quantity or type of waste disposal;
- D. A material change in the condition of the waters of the state; or
- E. Nonpayment of fees assessed pursuant to RCW 90.48.465.

Ecology may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

G4. REPORTING A CAUSE FOR MODIFICATION

The Permittee shall submit a new application, or a supplement to the previous application, along with required engineering plans and reports, whenever a material change in the quantity or type of discharge is anticipated which is not specifically authorized by this permit. This application shall be submitted at least 60 days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to Ecology for approval in accordance with Chapter 173-240 Washington Administrative Code (WAC). Engineering reports, plans, and specifications should be submitted at least 180 days prior to the planned start of construction. Facilities shall be constructed and operated in accordance with the approved plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in the permit shall be construed as excusing the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. DUTY TO REAPPLY

The Permittee must apply for permit renewal by **March 1, 2014**.

G8. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

G9. TOXIC POLLUTANTS

If any applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the Clean Water Act for a toxic pollutant and that standard or prohibition is more stringent than any limitation upon such pollutant in the permit, Ecology shall institute proceedings to modify or revoke and reissue the permit to conform to the new toxic effluent standard or prohibition.

G10. OTHER REQUIREMENTS OF 40 CFR

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

G11. ADDITIONAL MONITORING

Ecology may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

G12. PAYMENT OF FEES

The Permittee shall submit payment of fees associated with this permit as assessed by Ecology. Ecology may revoke this permit if the permit fees established under Chapter 173-224 WAC are not paid.

G13. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be and be deemed to be a separate and distinct violation.